

## **APPLICATION NOTES**

## Mets E100

**Metering Pump Station** 

**Application Range:** 18 gallons per day (24 hours). **Typical Silver Discharge:** 0.5 PPM to 1 PPM.

**Application Notes:** 

- Replace RePAC 250 cartridge every 400 gallons processed, or every 6 months.
- Clean out CT-5 tank and overflow fittings every 6 months.

## **Typical Installation:**

